

### 1. 기본 사양


용도	승객, 화물용 (적재지 겸용)
기종	MP20-CO-60-2F/2E
정격 하중	1350 KG (20인승)
정격 속도	60 M/MIN
구동 방식	VVVF
정지층 수	1F - 2F (2 STOP)
엘림 방식	2 DOOR 중앙개폐식
승강기 내 부크기	폭: 1400(1800)mm x 길이: 2130mm x 높이: 2400mm
출입문 크기	폭: 1000mm x 높이: 2100mm
승강문 내 부크기	폭: 2800mm x 길이: 2900mm (PIT 기준)
전고	24620 mm
행정거리	17620 mm
오버헤드	5000 mm
피트	2000 mm
모터용량	11 Kw
메인로프	Ø 10 x 7 본
완충기	CAR : SPRING , C.W.T : SPRING
레일	CAR : 24 Kg/M , C.W.T : 13 Kg/M
경보장치	전화 / 인터폰
동력전원	AC - 3PH 380V 60HZ
조명전원	AC - 1PH 220V 60HZ

### 2. 제작 사양

구분	항목	내용
지체 규격 및 재질	Car Panel	SUS-Vibration 1.5t & 접합유리 12t
	Car Door	SUS-Vibration 1.5t
	Car Floor	Aluminium check plate 3.0t
	Car Sill	경질 Aluminium
	Hall Door	SUS-Vibration 1.5t
제 질	Jamb	SUS-Vibration 1.5t
	Hall Sill	경질 Aluminium
기타 사항	이 중 천정	강판도장 & 아크릴
	Car Panel :	
	Car Door :	
	Etching 有, 無	Hall Door :

### 3. 건축반영사항

구분	점검 사항	점검 기준
승강로	오버헤드	최상층 바닥 마감면에서 승강문내 천정까지임
	피트	신디콘크리트 마감면에서 최하층 바닥까지임
	내부 벽면 및 바닥	침수없이 정결하고 돌출부위가 없을 것
	기타 설비	승강기와 관련된 배관, 배선이 없을 것


**ISO 9001**  
 KIS-B-302-4.2(0) 한글 인터넷 주소: (주)금호 엘리베이터 / 엘리베이터 / 덤웨이터 / 승강기 / 장애인용엘리베이터 / 수직리프트 / 물류자동운송

Rev. No. : 01  
 Date : 20090507  
 Drawn By : Byungil Park  
 Check By : Byungil Park  
 Appd By :  
 Send By : Byungil Park  
 Chkd By :  
 Comments :

http://www.kumhoellevator.co.kr  
**KUMHO ELEVATOR CO., LTD.**  
 E-Mail: kumho@kumhoel.com

1st Angle Projection  
 Unit : mm  
 Scale : N/S  
 Date : 20090507

Project : **성수대교남단**  
 Part : **LAV OUT**

Title : **시양사**  
 Project No. : KES-21-1004  
 Drawing No. : 1004-4-4-4  
 File Name : 02/04

Tel : 02-469-2080/855-006  
 Fax : 02-464-4183

ISO 9142mm x 2571